



Approval of the Trademark Trevira CS®

ArtimoTextiles b.v.
De Meeten 53
4706 NK Roosendaal
Netherlands

Application No.:	190890.1
Date of issue:	12.02.2021
Valid until:	14.08.2024
Article name:	Artiflame
End use:	Drapes
Square weight (g/m²):	47
<small>According to customer specification</small>	
Composition of the raw materials:	Polyester 100%
Composition of the fabric:	Trevira CS 100%

The article Artiflame col white has been tested under the Trevira trademark application no. 190890 and is granted approval for the trademark Trevira CS® for interior use. The article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507. The article meets the requirements for class 1 according to EN 13773. This article qualifies for class B-s1, d0 according to the European Standard EN 13501-1. Trevira CS has been approved by the DIBt with the General Building Inspectorate Approval, Approval No. Z-56.25-3573 dd. 24 April 2018.

Trevira GmbH
(This document is valid without signature.)

Trevira GmbH, Trademark Service, Max-Fischer-Straße 11, 86399 Bobingen, Germany
E-Mail: trademark.service@trevira.com