



Indorama Ventures Fibers Germany GmbH

Trademark Service

Max-Fischer-Str. 11

86399 Bobingen, Germany

trademarkservice.IVFG@de.indorama.net

Tel. +49 8234 9688 1673

www.indoramaventures.com



Approval of the Trademark Trevira CS®

ArtimoTextiles b.v.
De Meeten 53
4706 NK Roosendaal
Netherlands

Application No.:	260014.1 / 260015 / 220932.1
Date of issue:	05.02.2026
Valid until:	30.11.2027
Article name:	Dito
Color:	various
End use:	Drapes
Square weight (g/m²):	130
According to customer specification	
Composition of the raw materials:	100% Polyester
Composition of the fabric:	100% Trevira CS

The collection "Dito" is granted approval for the trademark Trevira CS® for interior use.

The approval of the collection is based on the trademark test results of application no.:
260014 col purple / 260015 col green / 220932 col dark yellow

These articles have been tested according to DIN 4102 part 1, 6.2 and thus also meet the requirements for fire class DIN 4102-B1.

This collection has been tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

This collection meets the requirements for class 1 according to EN 13773.

This collection qualifies for class B-s1, d0 according to the European Standard EN 13501-1. Trevira CS has been approved by the DIBt with the General Building Inspectorate Approval, Approval No. Z-56.25-3573 dd. 10 January 2024.

INDORAMA
VENTURES

Indispensable Chemistry



This collection can also meet the requirements for the fire index BKZ 5.3 (BKZ = fire index, combustibility 5 = flame retardant, level of smoke emission 3 = low smoke emission) according to the Swiss standard SN 198898.

This collection meets also the requirements for class 1 according to the Italian Standards UNI 8456 and UNI 8457.

This collection meets also the requirements according to British Standard BS 5867 part 2 type C.

This collection meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

Indorama Ventures Fibers Germany GmbH

(This document is valid without signature.)

260014.1 / 260015 / 220932.1

