

Exova Warringtonfire, Frankfurt
Industriepark Höchst C369
Frankfurt am Main
D-65926
Germany

T +49 (0) 69 305 3476
F +49 (0) 69 305 17071
E EBH@exova.com
W www.exova.com



Testing. Advising. Assuring.

Test report No. 2013-2333

for applying of a required "Verwendbarkeitsnachweis"
issued 23.02.2011

Applicant: Artimo textiles bv
de Meeten 53

NL-4706 NK Roosendaal

Date of order: 04.02.2011
Date of sampling: *no official sampling of the specimen by a representative of Exova Warringtonfire, Frankfurt*
Date of arrival: 07.02.2011
Date of test: 21.02.2011
Test report No.: 2011-1177-1

Order

Testing of the flammability (building class B1) according to DIN 4102-1 (May 1998)

Description / designation of the test object

Fabric sample designated as F100

Description of the relevant test procedure

DIN 4102 part 1 (Mai 1998)

This test report did not replace the required „Verwendbarkeitsnachweis“. It is only used for issuing the "Verwendbarkeitsnachweis".

Assessment

The material, described in chapter one fulfils the requirements of the building class B2 according to DIN 4102-1 (Mai 1998).

The determined test results show that the material also fulfils the requirements

of the building class B1

according to DIN 4102-1 (Mai 1998).

Special comment

The fire test result is only valid for the in chapter one described material in the tested colours in free hanging configuration.


The distance to other plane material must be more or equal then 40 mm.

The material wasn't tested after an outside storage.

In combination with other materials (for example coatings, deposits) the burning behaviour could be influenced unfavourable so that the classification above is not valid any longer. According to DIN 4102-1 the burning behaviour in combination with other materials has to be tested separately.

This test report did not replace the required „Verwendbarkeitsnachweis“. It is only used for issuing the “Verwendbarkeitsnachweis”.

Frankfurt, the 27.11.2013

A handwritten signature in blue ink, appearing to read "Anders Garcia".

H. Anders / A. Garcia
tester in charge

A handwritten signature in blue ink, appearing to read "Zachäus".

Dipl.-Ing. T. Zachäus
Laboratory Supervisor

This Test report is valid until 17.02.2016

The results of the tests relate only to the behaviour of the test specimen which is designated on the top.

Test reports are only allowed to be published or reproduced, not changed in form and tenor without permission of the Exova Warringtonfire, Frankfurt. The abridged account of a test report is only allowed with the agreement of the Exova Warringtonfire, Frankfurt.

This test report is a translation of the German version 2011-1177-2 (issued 27.11.2013). In case of doubt only the German version is valid

This test report contains 8 pages and 2 annexes.



LABORATOIRE CENTRAL
39 bis, rue de Dantzig - 75015 PARIS
Tél : 01 55 76 24 15
Mél : pp-labcent@interieur.gouv.fr - Site internet : www.lcpp.fr



MESURES PHYSIQUES ET SCIENCES DE L'INCENDIE
ESSAIS DE CONFORMITÉ ET EXAMEN DE MATÉRIELS

**PROCÈS-VERBAL DE CLASSEMENT
DE RÉACTION AU FEU D'UN MATÉRIAU
PRÉVU À L'ARTICLE 5 DE L'ARRÊTÉ DU 21 NOVEMBRE 2002
Valable jusqu'au 14 août 2017**

**PROCÈS-VERBAL N° 12/9097 /S-F -1
Délivré en extension au Procès-Verbal 12/9097**

MATÉRIAU présenté par : ARTIMO TEXTILES BV
DE MEETEN 53
4706 NK ROOSENDAAL

MARQUE COMMERCIALE : FLOO

DESCRIPTION SOMMAIRE : Tissu 100 % Polyester FR.
Épaisseur voisine de 0,53 millimètre
Masse au mètre carré : 264 grammes environ.
Coloris unis variés

NATURE DES ESSAIS : ESSAIS AU BRÛLEUR ÉLECTRIQUE ET ESSAIS COMPLÉMENTAIRES

CLASSEMENT M1

DURABILITÉ DU CLASSEMENT : Non limitée à priori

Ce procès-verbal atteste uniquement des caractéristiques de l'échantillon soumis aux essais et ne préjuge pas des caractéristiques de produits similaires. Il ne constitue donc pas une certification de produits au sens de l'article L. 115-27 du code de la consommation et de la loi du 3 juin 1994.

Fait à Paris, le 08/08/2013

Pour le Directeur,
l'adjoint au chef du pôle mesures physiques et
sciences de l'incendie

Laure MIMOUNI



Le responsable technique

Freddy MSIKA