



## Approval of the Trademark Trevira CS®

ArtimoTextiles b.v.  
De Meeten 53  
4706 NK Roosendaal  
Netherlands

<b>Application No.:</b>	190966.1
<b>Date of issue:</b>	04.11.2019
<b>Valid until:</b>	24.09.2024
<b>Article name:</b>	Gala
<b>End use:</b>	Drapes, printed Curtains, coloured Curtains, printed
<b>Square weight (g/m<sup>2</sup>):</b>	360
<b>According to customer specification</b>	
<b>Composition of fabric:</b>	Polyester 100% Trevira CS
<b>Yarn:</b>	Warp, 1340 f 320 x 1 dtex Trevira® Type art. T4M2W, Yarn supplier Trevira Weft, 1340 f 320 x 1 dtex Trevira® Type art. T492W, Yarn supplier Trevira

The tested article Gala with application no. 190966.1 is granted approval for the trademark Trevira CS® for interior use.  
This article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.  
This article meets the requirements according to EN 1021 part 1+2 in conjunction with polyurethan foams with a density of more than 30 kg/m<sup>3</sup>.  
The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.  
Thus meets also the requirements according to British Standard BS 5867 part 2 type C.  
Thus meets also the requirements according to British Standard BS 5852: ignition source 0 (cigarette), ignition source 1 (match) and ignition source 5 (crib 5) in conjunction with suitable combustion modified foams (at least 50 kg/m<sup>3</sup>).  
Thus meets also the requirements for class 1 according to the Italian Standards UNI VF 8456 and UNI VF 8457.  
The article was tested according to EN 1101 and thus also meets the requirements for class 1 according to EN 13773.  
Thus meets also the requirements according to the Italian standard UNI VF 9175, class 1 IM in conjunction with suitable combustion modified foams.

Trevira GmbH  
(This document is valid without signature.)