

MATERIAL REACTION TO FIRE CLASSIFICATION REPORT
PREPARED IN COMPLIANCE WITH AMENDED 5 OF THE FRENCH HOME OFFICE REGULATION
REGULATION DATED NOVEMBER 21ST, 2002 (OFFICIAL GAZETTE DATED DECEMBER 31, 2002)

Valid five years from issue date

CERTIFICATE N° 21-03120 L

And 1 Appendix of 6 pages

MATERIAL presented by: Artimo Textiles BV
De Meeten 53
4706 NK Roosendaal
The Netherlands

TRADE NAME: Lorens

BRIEF DESCRIPTION: fabric 100% inherent fire resistant polyester
Measured surface weight : About 300 g/m²
Measured thickness: About 0,7 mm
Colours : Various

TEST REPORT : N° 21-03120 on the October 22nd 2021

TESTS : Electrical burner test
Flame persistence test
Dripping test

CLASSIFICATION

M1

**Classification valid for any application for which the product is not subjected
to the CE marking of the Construction products**


CLASSIFICATION DURATION (article 5 of appendix 2) : unlimited unless otherwise specified

given the criteria resulting from the tests described in the enclosed test report.

The classification indicated does not mean that materials marketed comply with the test samples and must not be considered as a qualification certificate as defined by French law dated March 14, 2016.

N.B.: Only integral copies of this document may be made by photocopying the classification report and/or the classification report and enclosed test report.

Issued in Lyon, France, on the October 22nd 2021



Lucile MULTARI
Tests and Trials Engineer