



Approval of the Trademark Trevira CS®

ArtimoTextiles b.v. De Meeten 53 4706 NK Roosendaal Netherlands

 Application No.:
 190126.2

 Date of issue:
 05.10.2023

 Valid until:
 22.03.2024

Article name: Nolan
End use: Drapes
Curtains

Square weight (g/m²): 232

According to customer specification

Composition of the raw materials: Polyester 100% **Composition of the fabric:** Previra CS 100%

The article Nolan has been tested under the Trevira trademark application no. 190126 and is granted approval for the trademark Trevira CS® for interior use.

The article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

The article meets the requirements for class 1 according to EN 13773.

This article qualifies for class B-s1, d0 according to the European Standard EN 13501-1.

Thus meets also the requirements for class 1 according to the Italian Standards UNI 8456 and UNI 8457.

This article also meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

Indorama Ventures Fibers Germany GmbH (This document is valid without signature.)