



Approval of the Trademark Trevira CS®

ArtimoTextiles b.v. De Meeten 53 4706 NK Roosendaal Netherlands

Application No.:	210092.1
Date of issue:	15.02.2021
Valid until:	11.02.2026

Article name:PoriEnd use:CurtainsSquare weight (g/m²):172According to customer specificationPolyester 100%Composition of the raw materials:Polyester 100%Composition of the fabric:Trevira CS 100%

The article Pori has been tested under the Trevira trademark application no. 210092 and is granted approval for the trademark Trevira CS® for interior use.

The article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

Trevira GmbH (This document is valid without signature.)

> Trevira GmbH, Trademark Service, Max-Fischer-Straße 11, 86399 Bobingen, Germany E-Mail: <u>trademark.service@trevira.com</u>