



## Approval of the Trademark Trevira CS®

ArtimoTextiles b.v.  
De Meeten 53  
4706 NK Roosendaal  
Netherlands

<b>Application No.:</b>	230603.1
<b>Date of issue:</b>	24.07.2023
<b>Valid until:</b>	14.07.2028
<b>Article name:</b>	Roan
<b>End use:</b>	Drapes Curtains
<b>Square weight (g/m<sup>2</sup>):</b>	378
<b>According to customer specification</b>	
<b>Composition of the raw materials:</b>	Polyester 100%
<b>Composition of the fabric:</b>	Trevira CS 100%

The article Roan has been tested under the Trevira trademark application no. 230603 and is granted approval for the trademark Trevira CS® for interior use.

The article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

The article meets the requirements for class 1 according to EN 13773.

Thus meets also the requirements for class 1 according to the Italian Standards UNI 8456 and UNI 8457.

Thus meets also the requirements according to British Standard BS 5867 part 2 type C.

This article also meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

Indorama Ventures Fibers Germany GmbH  
(This document is valid without signature.)