



Approval of the Trademark Trevira CS®

ArtimoTextiles b.v.
De Meeten 53
4706 NK Roosendaal
Netherlands

Application No.:	240478.1
Date of issue:	09.05.2025
Valid until:	08.07.2029
Article name:	Seam
End use:	Curtains
Square weight (g/m²):	280
According to customer specification	
Composition of the raw materials:	100% Polyester
Composition of the fabric:	100% Trevira CS

The article Seam has been tested under the Trevira trademark application no. 240478 and is granted approval for the trademark Trevira CS® for interior use.

The article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

The article meets the requirements for class 1 according to EN 13773.

This article qualifies for class B-s1, d0 according to the European Standard EN 13501-1. Trevira CS has been approved by the DIBt with the General Building Inspectorate Approval, Approval No. Z-56.25-3573 dd. 10 January 2024.

Thus meets also the requirements according to British Standard BS 5867 part 2 type C.

Thus meets also the requirements for class 1 according to the Italian Standards UNI 8456 and UNI 8457.

This article also meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

Indorama Ventures Fibers Germany GmbH
(This document is valid without signature.)