

Trevira

Application for approval of the trademark TREVIRA®

Trevira GmbH
Markenprüfung /
Trademark Testing
Technikum, Gebäude 515
Max-Fischer-Straße 11
D-86399 Bobingen

Applicant

Company Artimo textiles
Road De Meeten 53
Post Code/City 4706 NK Roosendaal
Country the Netherlands

Name / Signature 7-10-2016 Artimo textiles

Trademark Trevira CS

Article Sumire

End Use Drapes

Other uses --

Composition 100% Trevira CS

Fabric weight (g/sm) 150

Yarn Details

Warp

Yarn titre/ count 60/2

Trevira Type 270

Yarn supplier Fil Man Made

Weft 1

Weft 2

Weft 3

Yarn titre/ count 60/2

Trevira Type 270

Yarn supplier --

Approval: 19.07.2016

(This Trademark approval is valid for a period of 5 years from the date of issue).

The tested article SUMIRE with application no. 161062 is granted approval for the trademark Trevira CS. This article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to EN 1101 and thus also meets the requirements for class 1 according to EN 13773.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

This article qualifies for class B-s1, d0 according to the European Standard EN 13501-1. Trevira CS has been approved by the DIBt with the General Building Inspectorate Approval, Approval No. Z-56.25-3573 dd. 2 May 2013.

M.M. 2016 i.A. B. van Kamen

Trevira GmbH, Trademark Service