



Approval of the Trademark Trevira CS®

ArtimoTextiles b.v. De Meeten 53 4706 NK Roosendaal Netherlands

Application No.: 181569.1 Date of issue: 12.04.2023 Valid until: 28.12.2023

Article name: WOOD End use: **Drapes** Curtains Square weight (g/m²): 90

According to customer specification

Composition of the raw materials: Polyester 100% Composition of the fabric: Trevira CS 100%

The article WOOD has been tested under the Trevira trademark application no. 181569 and is granted approval for the trademark Trevira CS® for interior use.

The article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

Thus meets also the requirements for class 1 according to the Italian Standards UNI 8456 and UNI 8457.

The article was tested according to EN 1101 and thus also meets the requirements for class 1 according to EN 13773.

This article qualifies for class B-s1, d0 according to the European Standard EN 13501-1. Trevira CS has been approved by the DIBt with the General Building Inspectorate Approval, Approval No. Z-56.25-3573 dd. 24 April 2018.

Trevira GmbH

(This document is valid without signature.)